



**KOMO®**  
 Technical approval-with-product certificate  
**K13789/13**



Issued 2018-12-15 Replaces K13789/12  
 Valid until Indefinite Dated 2017-02-15  
 Page 1 of 4

PEOC system

**hpg plastics gmbh**

STATEMENT BY KIWA

This technical approval-with-product certificate on the basis of BRL 5607 Plastics piping systems of PE-RT intended for heating installations: radiator connections issued on 25 October 2016 by Kiwa, in accordance with the Kiwa Regulation for Certification.

The quality system and the product characteristics belonging to the PEOC system are checked periodically and the performance of the PEOC system in the application as floor heating is assessed. The basic principles for the assessment are checked periodically.

Based on this Kiwa declares that :

- legitimate confidence exists that the by the holder of the technical approval- with-product certificate delivered PEOC system comply with :
  - the technical specifications as laid down in this technical approval-with-product certificate;
  - the product requirements as laid down in this technical approval-with-product certificate , provided that they have been marked the PEOC system with the KOMO®-mark in the manner as indicated in this technical approval-with-product certificate;
- the PEOC system provides the performances as described in this KOMO technical approval-with-product certificate, provided that:
  - the application conditions and technical specifications as described in this KOMO approval-with-product certificate are met;
  - the manufacturing takes place according to the processing methods as laid down in this technical approval-with-product certificate.

Within the framework of this KOMO technical approval-with-product certificate there is no inspections with regard to the production of other parts of the PEOC system or the processing of the PEOC system.

Ronald Karel  
 Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

474/18121

**CERTIFICATE**

**Kiwa Nederland B.V.**  
 Sir Winston Churchilllaan 273  
 Postbus 70  
 2280 AB RIJSWIJK  
 The Netherlands  
 Tel. +31 88 998 44 00  
 Fax +31 88 998 44 20  
 info@kiwa.nl  
[www.kiwa.nl](http://www.kiwa.nl)

**Holder of Certificate**  
 hpg plastics gmbh  
 Anna-Schlinkheider-Str. 3  
 40878 RATINGEN  
 Germany  
 Tel. +49(0)2102 / 7007 800  
 Fax +49(0)2102 / 7007 888  
 info@hpg-plastics.com  
 www.hpg-plastics.com



Evaluated is:  
 Quality system  
 Product  
 Performance in application  
 Periodic inspection

PEOC system

**Product characteristics**

The product complies to BRL 5607 Plastic piping systems of PE-RT intended for heating installations: radiator connections and BRL 5602 Plastic piping systems of PE-RT intended for floor heating..

The system consists of:

- PE-RT (type 1 & type 2) 5 layer pipes manufactured by hpg plastics gmbh (certificate K13788);
- Mechanical metal press and compression fittings manufactured by IPA (certificate K11612);
- Mechanical plastic pushfit fittings (15 x 1.7 mm) manufactured by John Guest (certificate K20907);
- Protection pipes manufactured by Maincor (certificate K11408);
- Protection pipes manufactured by Hegler Plastiks (certificate K13791).

**Specification**

The dimensions of the pipe in the table below are part of this certificate.

Class 5: Max. 4 bar		Class 5: Max. 6 bar		Class 4: Max. 6 bar		Class 4: Max. 10 bar <sup>1)</sup> PE-RT type 2	
Nominal outside Diameter (mm)	Wall thickness (mm)	Nominal outside Diameter (mm)	Wall thickness (mm)	Nominal outside Diameter (mm)	Wall thickness (mm)	Nominal outside Diameter (mm)	Wall thickness (mm)
10	1,3	10	1,3	10	1,3	10	1,6
15 <sup>2)</sup>	1,7 <sup>2)</sup>	12 <sup>3)</sup>	2,0 <sup>3)</sup>	12 <sup>3)</sup>	2,0 <sup>3)</sup>	12	2,0
20	2,0	14	2,0	14	2,0	14	2,0
32 <sup>4)</sup>	3,0 <sup>4)</sup>	15 <sup>3)</sup>	2,0 <sup>3)</sup>	15 <sup>2)</sup>	1,7 <sup>2)</sup>	15	2,5
		16	2,0	15 <sup>3)</sup>	2,0 <sup>3)</sup>	16	2,2
		17	2,0	16	2,0	18	2,5
		18	2,0	17	2,0	20	2,8
		20 <sup>1)</sup>	2,0 <sup>1)</sup>	18	2,0	22 <sup>4)</sup>	3,0 <sup>4)</sup>
		26	3,0	20	2,0	25	3,5
				26	3,0	26 <sup>4)</sup>	3,5 <sup>4)</sup>
				32 <sup>4)</sup>	3,0 <sup>4)</sup>	28 <sup>4)</sup>	4,0 <sup>4)</sup>
						32 <sup>4)</sup>	4,4 <sup>4)</sup>

<sup>1)</sup> only for PE-RT type 2

<sup>2)</sup> only for PE-RT type 1

<sup>3)</sup> only with compression fittings

<sup>4)</sup> only with press fittings

Colour: blue, yellow, green, opal, red, silver, white, black, orange, pink, grey.

Remarks: Metal press and compression fittings are being used for all diameters except 15 x 1.7 mm  
Plastic Pushfit fittings are used for the dimension 15 x 1.7 mm

**Marking**

The products shall be marked with the KOMO<sup>®</sup> mark.

**Pipes**

The minimum required marking on the pipes shall be:

- KOMO (or KOMO<sup>®</sup> word mark) + class 4 or 5/ 4, 6 or 10 bar;
- material identification: PE-RT type 1 or PE-RT type 2;
- the build up of the pipe; PE-RT /EVOH/PE-RT;
- certificate number of accompanying technical approval-with-product certificate of the piping system;
- the manufacturer's name, trade name, system name or logo;
- nominal outside diameter in mm;
- nominal wall thickness of the pipe in mm;
- production code.

The realization of the marks is as follows: clearly, durable and indelible at intervals of not more than 2 meters.



## PEOC system

---

### Fittings

The minimum required marking on the fittings shall be:

- KOMO (if not possible KOMO only on the smallest packaging);
- the manufacturer's name, trade name or logo;
- nominal outside diameter of the corresponding pipe;
- production code.

Location of the marks: on every fitting.

The realization of the marks is as follows: clearly, durable and indelible.

The minimum required marking on the smallest packaging unit of the fitting shall be:

- KOMO (or KOMO<sup>®</sup> word mark);
- certificate number of the accompanying technical approval-with-product certificate of the piping system, according the marking of the belonging pipe;
- the manufacturer's name, trade name, system name or logo;
- material identification if the fitting body is made of plastics;
- nominal outside diameter and nominal wall thickness of the corresponding pipe in mm.

Location of the marks: on every package.

The realization of the marks is as follows: clearly, durable and indelible on every packaging.

### Logistics

Production and assembly of the system is laid down in the annex of the certification agreement.

### PROCESSING

The supplier shall provide installation instructions, approved by Kiwa. A reference to these instructions shall be made at or near the packaging. The instructions are published in the Dutch language and contains at least specific information with regard to storage, transport, processing temperature and construction of the joints.

So-called "combination boilers" are often applied in individual house heating systems. In such boilers, no double separation between drinking water and heating medium exists. A leak in the single separation may result in the heating medium coming into contact with drinking water. Because of this it is important that in case additives are added to the heating medium a Kiwa product certificate for these additives has been issued.

The heat emission to the floor is dependent on the thickness of the finishing coat and the mutual distance between the pipes. The preconditions have to be clearly described in the instructions.

### PERFORMANCES

1. The system is oxygen tight.
2. All joints are leak tight and possess sufficient clamp force to resist external influences.

### PERFORMANCES OF THE PRODUCTS

All system components are designed for a lifetime of 50 years at an a operating temperature profile according to class 5 of NEN-ISO 10508 and an allowable working pressure of maximum 6 bar.

### RECOMMENDATION FOR THE CUSTOMER

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

Examine at delivery of the products mentioned under "processing" that they comply to the mentioned specifications.

If you should reject a delivery on the basis of the above, please contact:

- hpg plastics gmbh

and, if necessary:

- Kiwa Nederland B.V.

For the proper storage, transport and processing follow the instructions given under "processing".

Take notice of the application conditions given under "Performances in application".

